

# M F P A L e i p z i g G m b H

Recognised Test Office for Construction Materials, Components and Types

Test, Monitoring and Certification (PÜZ) Office according to the State Building Code (SAC 02),  
Building Product Law (NB 0800)



DAP-PL-4077.00

Test laboratory accredited by DAP GmbH according to DIN EN ISO/IEC 17025.  
The accreditation applies to the test methods listed in the certificate.

Business division II - Structural Engineering  
Head of Business division: Prof. Dr.-Ing. Olaf Selle

Work Group: Building Structure Sealing

Test Report: UB 2.2 / 07 – 161/1 dated September 13, 2007




Matter: *MPR Modular Wall and Casing Seal –  
Technical Application Leak Test*

**proved up to 5 bar**

Testing period: May to August 2007

Applicant: MPR SA, Gutehoffnungsring 74, D-57482 Wenden

Abstract: The sealing function of the *MPR Modular Wall and Casing Seal* was proven in a technical application test up to a water pressure of 5 bar and was documented in the above-mentioned test report.

Prof. Dr.-Ing. Selle  
Geschäftsbereichsleiter

Dipl.-Ing. Jüling  
Bearbeiter

Gesellschaft für Materialforschung und Prüfungsanstalt  
für das Bauwesen Leipzig mbH

Geschäftsführer: Jun.-Prof. Dr.-Ing. Frank Dehn  
Sitz: Hans-Weigel-Straße 2b · D - 04319 Leipzig  
Telefon: +49 (0) 341/65 82-140  
Fax: +49 (0) 341/65 82- 199  
E-Mail: abdichtung@mfpa-leipzig.de

Handelsregister:

Ust.-Nr.:  
Bankverbindung:

Amtsgericht Leipzig HRB 177 19

DE 813200649  
Sparkasse Leipzig  
Kto.-Nr 1100 560 781  
BLZ 880 555 92